

ARTISTIC FLOORING - San Fransisco Carpet Tile - Dry Carpet Pendulum Test

01 Feb 2017

CLIENT DETAILS & SITE INFORMATION :

This Report Is In Accordance with	AS 4586 (New)
Testing carried out using the DRY CARPET Test Method using	Slider 96 (4S) Rubber slider
Date Tested:	01 Feb 2017
Test Report Number:	KO010217-1
Client Name / Billing Address:	Artistic Flooring - 6/98 Ingleston Rd Wakerley Q 4154
CARPET Surface Tested / Underlay Type (if available)	San Francisco Carpet Tile Sample NO UNDERLAY PROVIDED

PRE-START CHECKLIST :

1. Level and Zero Pendulum at Start & Finish:	Checked
2a. Record ambient temperature (°C)	31
Temperature Correction for Type 55 (TRL) Rubber Slider	N/A
2b. Record weather	Indoors
3. Record Weight & Batch/Expiry of Sliders : Check Contact surface Under 4mm	Slider 96 (4S) 38g / #66
6. Slider conditioning value. #96 = 85 ± 10, #55 = 115 ± 10 Slider Contact area 126mm ± 1.0mm (124 ± 1.0mm) using the top of the slider as a guide	89
7. Lapping paper value - 10 swings (suggested values) #96 = 61 ± 3	58
9. Fixed Test	No - Tested in the Direction of least Anticipated Slip Resistance
Check Contact Slider Surface is	

VARIATIONS :




Total all Values	403
Mean Sample BPN (SRV) Surface Tested DRY	81
Variation of Standards	VARIATION OF STANDARDS - ONLY 1 SAMPLE AVAILABLE FOR TESTING
Mean Sample BPN (SRV) if Variation to Standards (Ignore above SRV)	81

YOUR RESULTS ARE :

Under 4586:2013 The Australian Standards Recommend for this area	N/A - No Information Provided
Using Slider 96 (4S) you have achieved a BPN of	P5 = >54 : "In-Line with R12 ref SA HB 198:2014"
*** Note *** 'R' RATINGS : Please note there is NO direct correlation between a R Rating and a P Rating (Wet Pendulum Test), however the "R" & "P" Ratings are in-line within the SA HB198:2014	
Do my Results meet the Australian Standards ?	N/A - No Information Provided

TEST INFORMATION & PICTURES :


Test Location & Pictures

Location	Grade Degrees	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN Test	Slope Correction Value (SCV)	Photo of Test Site
Sample tile 1	< 1.5	70	70	80	80	80	80	N/A	
Sample Tile 1 direction 2	< 1.5	70	79	80	82	82	81	N/A	
Sample Tile 1 Direction 3	< 1.5	70	75	79	79	79	79	N/A	
Sample Tile 1 Direction 4	< 1.5	69	74	77	77	78	77	N/A	
Sample tile 1	< 1.5	80	80	85	85	85	85	N/A	

SA HB 198:2014 - GUIDE TO THE SPECIFICATION AND TESTING OF SLIP RESISTANCE OF PEDESTRIAN SURFACES

SA HB 198:2014	Table 3B - Wet Pendulum Test or Oil-Wet Inclining Platform Classifications for Applications where the NCC does not require Slip Resistance
External Pavement and Ramps	N/A
Hotels, Offices, Public Buildings, Schools and Kindergartens	DRY - Entries and access read including hotels, offices, public buildings, schools, kindergartens, common areas of public buildings, internal lift lobbies = P1 or a R9
Supermarkets and Shopping Centres	N/A
Loading Docks, Commercial Kitchens, Cold Stores, Serving Areas	N/A
Swimming Pool and Sporting Facilities	N/A
Hospital and Aged Care Facilities	N/A

COMMENTS & SIGNATURE

Testing Officer :	Kathryn Ording
Pendulum machine in use - Caibration Date :	Munro Portable Skid Tester # 1133 - 24.08.2015
Additional Notes :	Wet situation = 4S Slider achieves a BPN of 60 (P5)
Testing Officer Signature	

The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Any enquiries in relation to this report should be directed to Sliptest Australia Pty. Ltd. quoting the applicable test report number.

Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999

This report and covering documentation was prepared by Sliptest Australia Pty. Ltd. on behalf of our client as named in the report. Neither Sliptest Australia Pty. Ltd. nor any person acting on our behalf (a) makes any warranty, express or implied, with respect to the use of any information or methods disclosed in this report or (b) assumes any liability with respect to the use of any information or methods disclosed in this report or covering information. Any recipient of this document, by their acceptance or use of this document, releases Sliptest Australia Pty. Ltd. and their affiliates from any liability for direct, indirect, consequential or special loss or damage whether arising in contract, warranty, express or implied, tort or otherwise, and irrespective of fault, negligence and strict liability.?

Declaration:

The factual matters stated within this report are, to the best of my knowledge, true and correct. I have completed all enquiries that I consider appropriate in formulating my conclusions.

The opinions stated by me within this report are genuinely held by me.

The report contains reference to all matter which I regard as significant.

I understand that my overriding duty as an expert is to assist the Court and have complied with this duty.